

LOT-NET


Advisory Board Meeting 5th October 2021

WP1.1, 1.2,1.3 and 2.2

Miguel Pans Castillo




Philip Eames


**Low Temperature Heat Recovery and Distribution
Network Technologies**




WP1: Heat mapping and analysis

Loughborough town






WP2: Methodology. DH system layout.




WP2: Methodology. Scenario 1: Heat required to meet demands.

Stage 1

Stage 2, scenario 1



WP2: Methodology. Scenario 2: Surplus heat produced.




WP2: Methodology. DH system optimisation.

The optimisation was done using the Microsoft Excel add-in program Solver. The Solver parameters introduced were:

- **Objective:** Cost per dwelling, to be minimum.
- **Variables:** the optimisation was carried out by modifying the following parameters:
 1. Installed capacity of PV used to power domestic HPs, ($PV_{\text{dwellings}}$).
 2. Installed capacity of Wind used to power domestic HPs, ($WIND_{\text{dwellings}}$).

The PV and Wind capacity needed to power the HTHPs required to lift the temperature of water prior charging the LTWT (PVLWT and WINDLTWT) are not included here, as these two are calculated depending on the amount of heat to be charged in the LTWT at every hour.

- **Constrains:** the following constraints were applied:
 1. Domestic heat demands to be met at every hour for the whole time-period considered for the simulation ($\Delta_{\text{dem-prod}} \leq 0$ kWh).
 2. $0.5 \text{ MW} \geq PV_{\text{dwellings}} \geq 0 \text{ MW}$.
 3. $0.5 \text{ MW} \geq WIND_{\text{dwellings}} \geq 0 \text{ MW}$.
 4. $0.05 \text{ LTWT}_{\text{max}} \geq \text{LTWT}_{\text{min}} > 0$, where LTWT_{min} is the minimum accumulated heat stored in LTWT between 01/09/2018 00:00:00 and 30/06/2019 23:00:00, and LTWT_{max} the maximum heat storage capacity of the LTWT. This last constraint was introduced to make the software find the solution faster and avoid local minimums, as it was observed that in all cases the global minimum cost that ensures to meet demands for the whole simulation period is obtained when the minimum heat stored in the LTWT between two summer maximums is the smallest possible (but higher than 0 kWh). In this case, it was assumed that the minimum should be less or equal than the 5% of the maximum heat storage capacity of the LTWT.



WP3: Applications to case-study regions. Case-scenario: 2 urban areas in Loughborough, UK (262 dwellings). Inputs.

City/town	Loughborough (UK)
Time-period considered	From 01/06/2018 00:00 to 31/12/2019 23:00



	RED AREA	BLUE AREA
Dwelling type		
detached	44.90%	46.20%
semidetached	29.20%	45.10%
terraced	15.70%	7.50%
flat	10.10%	1.20%
Total number of dwellings	89	173
Household type		
One person household	25.80%	17.90%
Married couple household	41.60%	49.10%
With dependent children	24.70%	20.20%
1	6.00%	10.95%
2	14.22%	5.89%
3	4.48%	3.36%
no dependent children	16.90%	28.90%
Same sex couple	0.00%	0.00%
With dependent children	0.00%	0.00%
1	0.00%	0.00%
2	0.00%	0.00%
3	0.00%	0.00%
no dependent children	0.00%	0.00%
Cohabiting couple	13.50%	14.50%
With dependent children	3.40%	8.70%
1	0.83%	4.72%
2	1.96%	2.54%
3	0.62%	1.45%
no dependent children	10.10%	5.80%
Lone parent	10.10%	16.70%
With dependent children	9.00%	12.10%
1	2.19%	6.56%
2	5.18%	3.53%
3	1.63%	2.01%
no dependent children	1.10%	4.60%
Multiperson household	9.00%	1.80%
Students	1.10%	0.60%
Other	7.90%	1.20%

[1] Official labour market statistics, NOMIS, (n.d.). <https://www.nomisweb.co.uk/>.

WP3: Applications to case-study regions. Case-scenario: 2 urban areas in Loughborough, UK (262 dwellings). Inputs.

RHSs main parameters

USED IN DWELLINGS

Renewable power sources used to power domestic HPs

Wind assumed installed capacity ($WIND_{DWEELLINGS}$, MW) 0 – 0.5

Solar PV assumed installed capacity ($PV_{DWEELLINGS}$, MW) 0 – 0.5

STCs

%ETSTC_{DWEELLINGS} 50%

%FPSTC 50%

Area of STC per dwelling (m²) 0 - 3

HPs

%ASHP 50%

%GSHP 50%

ASHPs capacity per unit (kW) As required

GSHPs capacity per unit (kW) As required

USED TO CHARGE LTWT

Renewable power sources used to power HTHPs needed to lift temperature of water prior

charging LTWT

Wind assumed installed capacity ($WIND_{LTWT}$, MW) As required

Solar PV assumed installed capacity (PV_{LTWT} , MW) As required

ETSTC_{LTWT} area (m²) As required

TES main parameters

Penetration (% of dwellings with stores)

STWT 50%

PCM 30%

LTWT NA

TCS 10%

Charging temperature (°C)

TCS 120

STWT 50

PCM 50

LTWT 50 - 90

Volume

STWT volume per dwelling (m³) 1

PCM volume per dwelling (m³) 1

TCS volume per dwelling (m³) 1

LTWT (m³) Variable

Methodology: Case-scenario: 2 urban areas in Loughborough, UK (262 dwellings). Inputs.

Piping network main parameters

Distance between Point 2 and Point 3 (m) ¹	80.5
Distance between Point 1 and Point 3 (m) ¹	291.5
Distance between Point 3 and LTWT (m) ¹	162.0
Inner diameter of pipes (m)	0.4
Thickness of pipes (m)	0.01
U-value (W/m K)	0.023[2]
Material	AluFlex[2]

Costs of variable parameters

Variable parameters

Installed PV (£/MW)[3]	1000000
Installed Wind (£/MW)[4]	1610000
LTWT (£/m ³)[5]	50
ASHPs (£/unit)	5000
GSHPs (£/unit)	13000
HTHPs (£/kW)[7]	250

Fixed parameters

TCS (£/m ³)[8,9]	100
PCM (£/kWh)[5]	45
STWT (£/m ³)[5]	30
Piping network (£/dwelling), [10,11]	800



- [2] M. Brand, J.E. Thorsen, S. Svendsen, Numerical modelling and experimental measurements for a low-temperature district heating substation for instantaneous preparation of DHW with respect to service pipes, *Energy*. (2012). <https://doi.org/10.1016/j.energy.2012.02.061>.
- [3] S.T.A. (STA), Solar Trade Association (STA), (n.d.). <https://solarenergyuk.org/>.
- [4] Briefings for britain, No Title, (n.d.). <https://briefingsforbritain.co.uk/>.
- [5] E. Guelpa, V. Verda, Thermal energy storage in district heating and cooling systems: A review, *Appl. Energy*. 252 (2019) 113474. <https://doi.org/10.1016/J.APENERGY.2019.113474>.
- [6] UK suppliers.
- [7] C. Arpagaus, F. Bless, M. Uhlmann, J. Schiffmann, S.S. Bertsch, High temperature heat pumps: Market overview, state of the art, research status, refrigerants, and application potentials, *Energy*. 152 (2018) 985–1010. <https://doi.org/10.1016/j.energy.2018.03.166>.
- [8] T. Yang, W. Liu, G.J. Kramer, Q. Sun, Seasonal thermal energy storage: A techno-economic literature review, *Renew. Sustain. Energy Rev.* 139 (2021) 110732. <https://doi.org/10.1016/J.RSER.2021.110732>.
- [9] F. Desai, J. Sunku Prasad, P. Muthukumar, M.M. Rahman, Thermochemical energy storage system for cooling and process heating applications: A review, *Energy Convers. Manag.* 229 (2021) 113617. <https://doi.org/10.1016/J.ENCONMAN.2020.113617>.
- [10] Energy technologies institute, DISTRICT HEAT NETWORKS IN THE UK: POTENTIAL, BARRIERS AND OPPORTUNITIES, (2018) 1–17. www.eti.co.uk (accessed August 18, 2021).
- [11] Energy research partnership, Potential Role of Hydrogen in the UK Energy System, 2016. <https://erpub.org/wp-content/uploads/2016/10/ERP-Hydrogen-report-Oct-2016.pdf>.

¹ Obtain by means of google maps.

WP2.2 Thermal Storage

- Large scale sensible heat store performance predictions, importance of SA/Vol Ratio, energy storage capacity, energy storage duration, losses
- Latent heat store designs, simulations and experiments for small capacity 5-10kWh stores with PCM temps less than 62°C. HX designs to provide specified power output rates.
- Thermochemical heat stores, materials $\text{MgCl}_2\text{SiO}_2$, MgSO_4 Zeolite charge/discharge characterisation and small scale lab systems. Larger systems modelled and to be built.


Extracted from James Delaney's MSc Thesis

COMSOL Modelling and Parametric Analysis of Thermochemical Energy Storage Systems and Their Domestic Applications

MgCl₂·2H₂O selected for storage material due to low cost, non-toxic, high energy density of 544kWhm⁻³ and equilibrium reaction temperature approximately 400K making it suitable for a domestic TCES reactor

At this temperature in the UK a Vacuum Flat Plate Solar Thermal Collector would be able to provide heat to the reactor.

Comsol model of a 1m³ volume packed bed reactor established,




Assumed reactive material density 1100kg/m³
Reactor energy storage density 254 kWh/m³

Boundary conditions

- The boundaries are perfectly impermeable except for the inlets and outlet for the reactor.
- Outlet pressure of the packed bed, as well as the initial pressure, is atmospheric, and the inlet pressure changes for variable mass flow rates.
- Zero heat flux across the boundaries of the reactor other than the inlet and outlet for the moist air.
- Constant inflow temperature of the air at 288.15K.
- Gravity acts with a constant acceleration of -9.81ms^{-2} in the x-direction of the geometry seen in Figure 1.
- Pellets are perfectly uniform in the reactor for a defined spherical radius.


Calculated power output with time for packed beds of different volumes.
Relative humidity of the moist air entering the reactor is 60% and the inlet temperature is 288.15K for an air mass flow rate of 170m³/hour.



A 1m³ store can store 254kWh

An 8m³ store can store over 2 MWh

Predicted air temperatures at outlet for mass flow rates from 150-200 m³/hour for a 1m³ store



Predicted temperatures in the packed bed at 18 hours of discharge

